



Pre No. CC231303-02-R0

SPECIAL SEISMIC CERTIFICATION CERTIFICATE OF COMPLIANCE

Equipment Manufacturer


Manufacturer: Evenlite, Inc.
Model Line: Pure Wave Mini, LiteMinder, LiteMinder Modular
Product Type: Lighting Inverter Systems
Address: 2575 Metropolitan Drive
Trevose, PA 19053
Phone: (800) 872-0879
Website: www.evenlite.com

Certification Agency

Issue Date: 5-Apr-2023
Expiration Date: 5-Apr-2028
Agency Name: Pre Compliance
Address: 36 SW Wall Street
Bend, OR 97702
Phone: (541) 241-2310
Website: www.go-pre.com

Seismic Certification Parameters

Method of Certification: Shake Table Testing
Assessment Standard: ICC-ES AC156
Mounting Configuration: Varies - See Product Tables
Building Codes: IBC 2021, CBC 2022
Importance Factor (I_p): 1.5
 S_{DS} for $z/h = 1$: 2.00 g
 S_{DS} for $z/h = 0$: 2.00 g
 A_{flx-h} : 3.20 g **A_{flx-v} :** 1.33 g
 A_{rig-h} : 2.40 g **A_{rig-v} :** 0.53 g



Certification Terms

1. For specific models covered under this certification, see Table of Certified Components and Subcomponents accompanying this certificate.
2. For products with $I_p \geq 1.0$, the product is expected to retain position following the design earthquake and is not expected to pose a threat to life and limb.
3. For components with $I_p = 1.5$ and certified by testing, the component is expected to remain operational following the design earthquake. Limited structural yielding is expected and minor repairs may be required.
4. This certification is dependent on proper mounting and anchorage in the listed mounting configuration(s). This certification does not specify anchorage design due to the variability of supporting structure and substrate conditions that may be present at the installation location.
5. Certified products are approved for the Building Codes listed and previous editions of those codes. Extension of this certificate to other Building Codes requires assessment of parameters by Pre Compliance. The seismic levels listed are valid for all soil types and seismic design categories.

Approval

I attest that I have impartially reviewed the documentation supporting this special seismic certification and have confirmed it is in general conformance with the referenced codes and standards and that it meets the seismic levels required for the listed site.

Signature:

Name: Andy Coughlin, SE
Title: Principal Engineer
Email: andy@go-pre.com
Phone: (415) 635-8461
License: S6082 (California)

