



Pre No. CC251834-01-R1

SPECIAL SEISMIC CERTIFICATION CERTIFICATE OF COMPLIANCE

Equipment Manufacturer


Manufacturer: Eaton Electric Oy
Model Line: 93PM
Product Type: UPS
Address: Riistakuja 1
01740 Vantaa, Finland
Phone: +358 (0) 9 452 661
Website: www.eaton.com

Certification Agency

Issue Date: 28-Jan-2026 (Revised 5-Feb-2026)
Expiration Date: 28-Jan-2032
Agency Name: Pre Compliance
Address: 324 NW Hill Street
Bend, OR 97703
Phone: (541) 241-2310
Website: www.go-pre.com

Seismic Certification Parameters

Method of Certification: Analysis
Assessment Standard: Eurocode 8 (2004)
Mounting Configuration: Base Mounted - Rigid
Building Codes: Eurocode 8 (2004)
Importance Class (IC): IV and II
Design Ground Acceleration (a_g): 0.30 (IC IV Type I), 0.26 (IC IV Type II)
0.20 (IC II Type I), 0.17 (IC II Type II)
Soil Factor (S): 1.15 (Type I), 1.5 (Type II)
Corner Periods for Type I
Elastic Response Spectra: $T_B = 0.2$ sec., $T_C = 0.6$ sec.,
 $T_D = 2$ sec.
Corner Periods for Type II
Elastic Response Spectra: $T_B = 0.1$ sec., $T_C = 0.25$ sec.,
 $T_D = 1.2$ sec.
Damping Value (η): 1



Certification Terms

1. For specific models covered under this certification, see Table of Certified Components and Subcomponents accompanying this certificate.
2. For products certified by analysis, the product is expected to retain position following the design earthquake and is not expected to pose a threat to life and limb.
3. This certification is dependent on proper mounting and anchorage in the listed mounting configuration(s). This certification does not specify anchorage design due to the variability of supporting structure and substrate conditions that may be present at the installation location.
4. Certified products are approved for the Building Codes listed and previous editions of those codes. Extension of this certificate to other Building Codes requires assessment of parameters by Pre Compliance.

Approval

I attest that I have impartially reviewed the documentation supporting this special seismic certification and have confirmed it is in general conformance with the referenced codes and standards.

Signature:

Name: Andy Coughlin, SE
Title: Principal Engineer
Email: andy@go-pre.com
Phone: (415) 635-8461
License: S6082 (California)

